

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM
LISTING SERVICE

LISTING No. 7260-1508:102

Page 1 of 1

CATEGORY: Beam Smoke Detection System

LISTEE: Fire Fighting Enterprises Ltd., 5 Wedgewood Crt Wedgewood Way
Stevenage, Hertfordshire, England SG1 4QR
Contact: Don Campbell 44 (0) 1438 317216 Fax 44 (0) 1438 722136

DESIGN: Models*50RU and *100RU Projected Beam Smoke Detectors. Units consist of a combined transmitter/receiver and reflector prism. Refer to listee's data sheet for detailed product description and operational considerations.

RATING: 10.2 – 30 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, rating, and UL label.

APPROVAL: Listed as projected beam smoke detection system for use with separately listed compatible control units. Authority having jurisdiction should be consulted prior to installation. Refer to listee's Installation Instruction Manual for details.

*Rev. 04-28-04



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **APRIL 28, 2004**

*Listing Expires **June 30, 2004***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**